


FIRE ALARM DEVICE	BOX REQ'MENT	MOUNTING HEIGHT
Pull Station	Standard 4square w/ Single Gang Mud Ring	44" A.F.F. TO CENTER FOR ADA REQ'MENTS
Ceiling Mount Speaker/Strobe Spkr = 25VAC	T-Bar Hangar w/ Deep 4square	FLUSH W/ FINISHED CEILING
Ceiling Mt. MNS Strobe Only	T-Bar Hangar w/ 4square	FLUSH W/ FINISHED CEILING
Ceiling Mt. FIRE Strobe Only	T-Bar Hangar w/ 4square	FLUSH W/ FINISHED CEILING
Ceiling Spkr/Strobe Spkr = 25VAC	T-Bar Hangar w/ Deep 4square	FLUSH W/ FINISHED CEILING
Cone Directional Speaker Horn Spkr Horn = 25VAC	Standard 4square	96" A.F.F. TO TOP
M = MNS Wall Mt. Strobe Only F = FIRE Wall Mt. Strobe Only	Standard 4square w/ Single Gang Mud Ring	80" A.F.F. TO THE BOTTOM
4" Speaker Only 8" = Denotes 8" Spkr Spkr = 25VAC	T-Bar Hangar w/ Deep 4square	FLUSH W/ FINISHED CEILING
Speaker/Horn Spkr Horn = 25VAC	Deep 4square w/ Single Gang Mud Ring	80" A.F.F. TO THE BOTTOM
Sprinkler Bell	Weather Proof Standard 4square	96" A.F.F. TO TOP
Heat Detector	T-Bar Hangar w/ 4square	FLUSH W/ FINISHED CEILING
Smoke Detector	T-Bar Hangar w/ 4square	FLUSH W/ FINISHED CEILING
Supply/Return Duct Detector	Advanced Supplied Duct Detector Housing	
Relay Module	Deep 4square	MOUNT RELAY FOR SHUTDOWN WITHING 3' OF UNIT CONTROLS.
Monitor Module	Deep 4square	54" A.F.F. TO CENTER
Control Module	Deep 4square	54" A.F.F. TO CENTER
Lightning Protection Module	Advanced Supplied Enclosure	54" A.F.F. TO CENTER
Flow Switch	ACTUAL SWITCH PROVIDED BY SUPPRESSION CONTR.	
Tamper Switch	ACTUAL SWITCH PROVIDED BY SUPPRESSION CONTR.	
Fire Alarm Control Panel	Advanced Supplied Enclosure	54" A.F.F. TO BOTTOM
Fire Alarm Annunciator Panel	Advanced Supplied Enclosure	54" A.F.F. TO CENTER
Fire Alarm Remote Power Supply	Advanced Supplied Enclosure	54" A.F.F. TO BOTTOM
Local Operating Control (LOC)	Advanced Supplied Enclosure	54" A.F.F. TO CENTER
Voice Communication Box Amplifier = 25VAC	Advanced Supplied Enclosure	54" A.F.F. TO BOTTOM
	FIRE ALARM VOICE EVACUATION SYSTEM DEVICE BOX SCHEDULE	DRAWN BY: ADAM WINBURY CHECKED BY: DAVID MAYBERRY DATE: 1-10-2011 REV: NONE REV. DATE: N/A