FIRE ALARM DEVICE	BOX REQ'MENT	MOUNTING HEIGHT
Pull Station	Standard 4square w/ Single Gang Mud Ring	44" A.F.F. TO CENTER FOR ADA REQ'MENTS
Ceiling Mount Horn/Strobe	T-Bar Hangar w/ Standard 4square	FLUSH W/ FINISHED CEILING
Ceiling Mt. MNS Strobe Only	T-Bar Hangar w/ 4square	FLUSH W/ FINISHED CEILING
Ceiling Mt. FIRE Strobe Only	T-Bar Hangar w/ 4square	FLUSH W/ FINISHED CEILING
M = MNS Wall Mt. Strobe Only F = FIRE Wall Mt. Strobe Only	Standard 4square w/ Single Gang Mud Ring	80" A.F.F. TO THE BOTTOM
Cone Directional Speaker Horn	Standard 4sqaure	96" A.F.F. TO TOP
Sprinkler Bell	Weather Proof Standard 4square	96" A.F.F. TO TOP
Heat Detector	T-Bar Hangar w/ 4square	FLUSH W/ FINISHED CEILING
Smoke Detector	T-Bar Hangar w/ 4square	FLUSH W/ FINISHED CEILING
Supply/Return Duct Detector	Advanced Supplied Duct Detector Housing	
Relay Module	Deep 4square	MOUNT RELAY FOR SHUTDOWN WITHING 3' OF UNIT CONTROLS.
Monitor Module	Deep 4square	54" A.F.F. TO CENTER
Control Module	Deep 4square	54" A.F.F. TO CENTER
Lightning Protection Module	Advanced Supplied Enclosure	54" A.F.F. TO CENTER
Flow Switch	ACTUAL SWITCH PROVIDED BY SUPPRESSION CONTR.	
Tamper Switch	ACTUAL SWITCH PROVIDED BY SUPPRESSION CONTR.	
Fire Alarm Control Panel	Advanced Supplied Enclosure	54" A.F.F. TO BOTTOM
Fire Alarm Annunciator Panel	Advanced Supplied Enclosure	54" A.F.F. TO CENTER
Fire Alarm Remote Power Supply	Advanced Supplied Enclosure	54" A.F.F. TO BOTTOM

ADVANCED
CABLING • FIRE • SECURITY

FIRE ALARM SYSTEM DEVICE
BOX SCHEDULE

DRAWN BY: ADAM WINBURY
CHECKED BY: DAVID MAYBERRY
DATE: 1-10-2011
REV: NONE
REV. DATE: N/A